

Washington Metropolitan Area Transit Authority  
**Board Action/Information Summary**

<input checked="" type="radio"/> Action <input type="radio"/> Information	MEAD Number: 100486	Resolution: <input type="radio"/> Yes <input checked="" type="radio"/> No
---	------------------------	--

**TITLE:**

Modify FQ6002 Additional Fire Line POC #37

**PURPOSE:**

To obtain Board approval to modify contract FQ6002 - Fire Standpipe Rehabilitation - Install Additional Fire Standpipe at Pentagon Station. The total value of this modification total value not to exceed \$150,000.

**DESCRIPTION:**

Modify Contract FQ6002 - Fire Standpipe Rehabilitation - Install additional fire standpipe at Pentagon Station. The total value of this modification is not to exceed \$150,000. Section of embedded fire line standpipe at the Pentagon Station required rehabilitation. After inspection of the pipe and discussions with maintenance personnel, it was decided that the most cost effective way to rehabilitate this section of embedded fire line was to provide a surface-mounted replacement.

This item was originally included in the proposed Capital Plan of Contracts that was deferred at the Finance, Administration and Oversight (FAO) Committee on September 10, 2009. This is a priority contract and is being submitted individually because Board-approval of the Plan will not be considered until October, 2009. The contract modification is item number 37 in the amount of \$150,000 on the Plan of Contracts submitted to the FAO Committee on September 10, 2009.

**FUNDING IMPACT:**

Program:	FY2010 Capital Improvement Program
Project:	Fire System Rehabilitation PE_FIRE
Budget:	\$5,362,619.00
This Action:	150,000.00
Prior Approval:	4,875,000.90
Remaining Budget:	\$337,618.10
Remarks:	
Operating Budget Impact:	No impact on the operating budget

**RECOMMENDATION:**

Approval to modify contract FQ6002 - Fire Standpipe Rehabilitation - Install Additional Fire Standpipe at Pentagon Station. The total value of this modification is not to exceed \$150,000.