IFB Solicitation Number IFB CQ16084/CPR
Date of Issue: March 1, 2016
IFB Opening Closing Date: March 9, 2016

## WASHINGTON METROPOLITAN AREA TRANSIT AUTHORITY 600 FIFTH STREET, N.W. WASHINGTON, DC 20001

March 1, 2016

AMENDMENT NO. 1 TO Rail Tunnel Light Project

## TO WHOM IT MAY CONCERN:

- A. The solicitation documents accompanying solicitation IFB CQ16084/CPR are hereby revised/changed in part as follows:
- 1. Responses to questions submitted by 12 PM, February 29, 2016 are attached.

Original signed March 2, 2016
Laura Marshall Date
Contracting Officer

## B. ACKNOWLEDGMENT

Proposers are required to acknowledge receipt of Amendment 1 in writing on the Solicitation Form (Acknowledgement of Amendments, page 17 in the solicitation), in the space provided below or by separate letter or facsimile.

Name	Date
Company Name	

1. **Question** - Is there a model number on the4 lights that are needed?

**Response** – The lights need to meet the specifications provided in the Technical Specifications, page 90.

2. **Question** - Why is WMATA specifying a fluorescent fixture and not an LED fixture?

**Response** – LED lights and components are currently being tested but have not be approved by WMATA engineers for use throughout the WMATA tunnel system.

3. **Question** – What is the kelvin color for the 28w lamps?

Response – The T5 lamps (28W) are 4100K